

## NDLAMBE MUNICIPALITY



### INVITATION TO SUBMIT FORMAL WRITTEN QUOTATIONS – REPAIRS ON HIGH MAST LIGHTS IN ALEXANDRIA, MARSELLE AND PORT ALFRED

Specification:

AREA	HIGH MAST NUMBER / STREET	NO OF LIGHTS TO BE REPAIRED
KwaNonkqubela, Alexandria	No:004	6 flood lights to be repaired
Marselle	No:001	3 flood lights to be repaired
Nemato, Port Alfred	Ntontela Street	6 flood lights to be repaired
	Mgudwa Street	2 flood lights to be repaired
	Ngxokolo Street	4 flood lights to be repaired
	Mbundwini Street	4 flood lights to be repaired
New Rest, Port Alfred	No: 012	8 flood lights to be repaired
	No:013	7 flood lights to be repaired

#### **The following is applicable to the existing high mast fitting details:**

- Lighting tubes are 1000/400 watts Nav – (Son –T) Tubular high pressure sodium or metal halide screw light.
- The glass cover is heat tempered, impact resistant borosilicate sealed to the body with a silicone rubber gasket.
- Lamp holders are made of porcelain.
- All exterior fasteners are made of stainless steel.
- The control gear is housed in a die cast aluminium box that is gasket and sealed against the ingress of dust and moisture.
- The housing is located on top of each luminaire.
- Electrical connection is in a 6 way 30 Amperes terminal block inside the control gear box.
- Entry to the terminal block is via a 20mm nylon compression gland with a heat resistant cable.
- Connections to the power supply are through the distribution board (D/B) on the inside of the pole at the base and are accessible through the metal door.
- It should be noted that it is of the utmost importance that all maintenance and repairs carried out must ensure that the same quality of the material been used. Should this not be possible due to the material being scares any alternative to be used must be approved by the electrician of Ndlambe Local Municipality.

#### **Equipment and Material replaced**

- All the equipment installed as part of the repairs and maintenance of high mast light must ensure satisfactory and continuous operation of the lights.
- All equipment and material must be suitable for operation of the lights under all working conditions.
- Bidders are to provide their own equipment to lower mast.

#### **Bidders Shall Take Note of the Following Bid Conditions:**

1. Prices must be valid for at least 90 days from the closing date.
2. Prices quoted must be firm and must be inclusive of VAT.
3. Bids not complying with all specifications as set out above will be declared non-responsive and therefore not be considered for the preferential point's calculation which will be used to determine the successful bidder.
4. Ndlambe Municipality does not bind itself to accept the lowest bid or any other bid and reserves the right to accept the whole or part of a bid.
5. Bids that are late will not be considered, whilst the lowest or only quotation will not necessarily be accepted. Quotations per fax or E-mail will also not be considered.

6. An original tax clearance certificate issued by SARS must accompany all quotations OR a tax reference number and PIN or TCC number must be provided.
7. Bidders must complete Council's Declaration of Interest form (**MBD4**).
8. Bidders must complete Certificate of Independent Bid Determination (**MBD9**).
9. Bidders who wish to claim for preferential points in terms of the Preferential Procurement Regulations, 2017, must submit a completed form **MBD 6.1** as well as a **certified copy** of the proof of B-BBEE status level of contribution.
10. It should be noted that the 80/20 points system will be applied, 80 being for price and 20 for the B-BBEE status level as defined in the Preferential Procurement Regulations, 2017.
11. The award will be made in terms of the Municipality's Supply Chain Management Policy.
12. A Municipal Billing Clearance Certificate (in respect of both the company and, if applicable, directors/owners) must accompany all bids.
13. Evidence of registration of company on the Central Supplier Database (CSD) must be provided (Supplier Number).
14. Failure to comply with above conditions will result in a disqualification of the bid.
15. Tenderer must be registered with the CIDB and have a valid CIDB contractor grading designation of grade 1EP/1EB

All quotations should be placed in a sealed envelop marked "**REPAIRS ON HIGH MAST LIGHTS**" and must be placed in a tender box in the Supply Chain Offices, Campbell Street, Port Alfred not later than 12H00 , 27 August 2020.

Further details may be obtained from Mr S Runeli at 073 439 8482 or email: [sruneli@ndlambe.gov.za](mailto:sruneli@ndlambe.gov.za)

**NOTICE NUMBER:136 /2020**  
**19 August 2020**

**ADV. R DUMEZWENI**  
**MUNICIPAL MANAGER**

=====

**To be displayed on all municipal boards**